

WRAS[®]

Water Regulations Advisory Scheme

This certifies that
EUROPEAN WATER CARE LTD

*has had the undermentioned product examined, tested
and found, when correctly installed, to comply with
the requirements of the United Kingdom Water Supply
(Water Fittings) Regulations/Scottish Water Byelaws.*

FH5, FH10, FH 10 LOWLINE, FH18, FH23 & FH30 FILTER HOUSINGS.

Reference should be made to the accompanying acceptance letter for installation requirements

*The product so mentioned will be listed in the
Water Fittings and Materials Directory
for a period until:*


21 JULY 2014

0907076

Certificate No.



Chairman, Test and Assessment Group



Secretary

WRAS
**APPROVED
PRODUCT**

Ref. No: 0907076
Sample No: 08613B

24th August 2009

Robert Mallerman
European Water Care Ltd
Regal House
South Road
Harlow
Essex
CM20 2BL

Dear Robert Mallerman

FILTERS AND HOUSINGS

1. Samples of the fittings or units described below have been subjected to relevant tests and examinations contained in the "Regulators' specifications", and after considering the test reports the Technical Committee's Product and Assessment Group (PAG) of the Water Regulations Advisory Scheme (WRAS or "the Scheme") finds that the fittings or units so described comply with, and their use when correctly installed, does not contravene the requirements of The Water Supply (Water Fittings) Regulations 1999, The Water Byelaws 2004 Scotland, and The Water Regulations (Northern Ireland) 1991.

0907076

FILTERS AND HOUSINGS

1050

IRN R001, R170

Tradename:

Range of filter housings with polypropylene head, EPDM 'O' rings. Inlets incorporate single check valve cartridges (Barberi Srl) (suitable for backflow protection against Fluid Category 2). Maximum working pressure 6.0 bar. Minimum working pressure 1.5 bar. Cold water use only.

Size: 3/4" BSP.

Model: FH5, FH10, FH 10 Lowline, FH18, FH23, FH30.

Marking: Pentair Water or Covess and product information printed on adhesive label on body and head.

Manufacturer: European Water Care Ltd.

2. Installation Requirements & Notes are set out on Page 3.